2013 LEBANON TN SSOER

*Map Ref. #	Address/ Location	Date	Duration of Overflow (hrs)	Estimated Volume (gallons)	Basin	Cause of the Overflow	Measure taken to stop the Overflow	Short Term Control List	Long Term Planning and Remediation	Manhole #
	Rainfall Related									
1	Alhambra	1/13/13	unknown, estimated 5 hours	estimated 300+ gpm	Alhambra	I & I from heavy rainfall	Treatment plant optimized flow throughput to reduce sewer surcharges		X	2378
1	Alhambra	1/16/13	unknown, estimated 9 hours	estimated 300+ gpm	Alhambra	I & I from heavy rainfall	Treatment plant optimized flow throughput to reduce sewer surcharges		X	2378
1	Alhambra	4/28/13	unknown, estimated 6 hours	unknown	Alhambra	I & I from heavy rainfall	Treatment plant optimized flow throughput to reduce sewer surcharges		X	2378
1	Alhambra	12/6/13	10 hours 30 minutes	estimated 200gpm	Alhambra	I & I from heavy rainfall	Treatment plant optimized flow throughput to reduce sewer surcharges		X	2378
2	337 W. Baddour Pkwy	4/27/13	unknown, estimated less than 12 hours	estimated 1gpm	Coles Ferry	I & I from heavy rainfall	No immediate action taken. Pipeline investigation underway.		X	36935
3	608 Fairground Ct.	4/27/13	unknown, estimated less than 12 hours	estimated 10gpm	Coles Ferry	I & I from heavy rainfall	No immediate action taken. Rehabilitation project identified. Planning underway.		X	1753
3	608 Fairground Ct.	8/8/13	6 hours 35 minutes	estimated 50 gallons	Coles Ferry	I & I from heavy rainfall	No immediate action taken. Rehabilitation project identified. Planning underway.		X	1753
3	608 Fairground Ct.	12/6/13	11 hours 45 minutes	estimated at 200gpm	Coles Ferry	I & I from heavy rainfall	No immediate action taken. Rehabilitation project identified. Planning underway.		X	1753
4	Spence Creek Pump Station #55	8/8/13	1 minute	estimated 50 gallons	Spence Creek	heavy rainfall floated pump station up/unhooked pipes. Not I&I related.	made repairs to pump station	X		PS #55
5	N. Maple St.	12/6/13	5 hours 45 minutes	estimated at 200gpm	Sinking Creek	I & I from heavy rainfall	No immediate action taken. Pipeline investigation underway.		X	534
6	N. Greenwood St.	12/6/13	unknown, estimated less than 12 hours	unknown	Coles Ferry	I & I from heavy rainfall	No immediate action taken. Pipeline investigation underway.		X	587
	Non- Rainfall Related									
7	76 Truck Stop Pump Station/Hwy 109	1/14/13	unknown, estimated less than 12 hours	estimated at <5gpm	Bartons Creek	stopped up check valve	repaired pump station	X		PS #16
8	Hwy 231 N. beside Wilson Co. Jail	1/18/13	44 minutes	estimated 100 gallons on road	Sinking Creek	debris in line from jail	unstopped main line	X		1813
8	Hwy 231 N. beside Wilson Co. Jail	10/25/13	22 minutes	estimated <5gpm	Sinking Creek	debris in line from jail	unstopped main line	X		1813
9	W. Main St. & Castle Heights Ave.	3/5/13	45 minutes	estimated 5gpm	Tarver Branch	const. company left test ball in line	released air off plug	X		1143
10	401 S. Cumberland St. (Whitt's BBQ)	3/8/13	28 minutes	estimated .5gpm	Sinking Creek	main line stopped up	cleaned grease from main line	X		556
11	2896 Hickory Ridge Rd.	4/1/13	30 minutes	estimated 5gpm	Bartons Creek	main line stopped up	cleaned grease from main line	X		919
12	319 E. Main St.	4/10/13	37 minutes	estimated 5gpm	Sinking Creek	main line stopped up	cleaned lint from main line	X		none
13	Leeville Pike Pump Station #4	4/26/13	19 minutes	estimated 10gpm	Bartons Creek	pumps not working	pumped down by hand/repaired station	X		PS #4
14	Horn Springs Pump Station #56	5/6/13	30 minutes	1gpm	Horn Spings	pump station power out	replaced blown fuses	X		PS #56
15	1103 W. Baddour Pkwy	6/10/13	1 hour 46 minutes	estimated 20 gpm	Bartons Creek	main line stopped up	cleaned grease from main line	X		224
16	Castlewood Pump Station #21	7/22/13	27 minutes	estimated 15gpm	Tarver Branch	broken line on pump	contractor made repairs	X		PS #21
17	Hwy 231 N. beside Wilson Co. Jail	7/25/13	1 hour 50 minutes	estimated 1gpm	Sinking Creek	debris in line from jail	unstopped main line	X		1812
18	112 W. Lester Ave.	7/29/13	45 minutes	estimated 1gpm	Sinking Creek	main line stopped up	cleaned main line	X		1775
19	Iroquois Pump Station #38	8/7/13	1 minute	estimated total 50 gallons	Spence Creek	main breaker off at pump station	turned breaker back on	X		PS #38
20	5776 E. Division St.	8/15/13	1 hour 46 minutes	estimated 1gpm	Bartons Creek	force main had small split in it	repairs made in parking lot	X		none
21	1050 Bluebird Rd.	11/20/13	46 minutes	estimated 5gpm	Sinking Creek	large amount of grease	unstopped main line	X		between 387-1879